

## Minimum Separation Distances from Septic Systems

The below listed minimum separation distances as stipulated in North Carolina General Statutes 130A-335 (e), (f), are the **most commonly used** in planning for a home or small business. If there are specific questions or unusual situations on your proposed or existing building lot, check with the health department for specific circumstances.

|                                 |          |
|---------------------------------|----------|
| Any private water supply source | 100 feet |
| Any public water supply source  | 100 feet |
| Any lake or pond                | 50 feet  |
| Any building foundation         | 5 feet   |
| Any basement                    | 15 feet  |
| Any property line               | 10 feet  |
| Any swimming pool               | 15 feet  |